



TYPICAL ELEVATION

Note:

Firestopping
Required
Vertically every
10' on exterior
stud walls

Firestop Materials Accepted:

1. Nominal 2" Lumber
2. 3/4" Plywood with backed joints
3. 1/2" Gypsum Board with joints backed or taped
4. Unfaced fiberglass batt insulation shall fill the entire cross section of the wall cavity to a minimum height of 16" down from the top of the wall and be securely retained in place.